



INSPECTION REPORT

Report Issued: Mar 20, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH250018

Issuance Date: Jan 10, 2025

Property Address: 355 RIVERVIEW WAY;

Applicant: Air Comfort, Inc.

Contractor: Air Comfort, Inc. 150 ROME COURT, 150 Rome Court FT. COLLINS, CO 80524

To construct: HVAC Mechanical

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 3rd floor above ceiling duct work has been installed, supported and sealed correctly. All radiation dampers are installed per plans. AC line sets for 3rd floor are installed correctly with all pressure tests good at 300 psi. Partial approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us