



# INSPECTION REPORT

**Report Issued:** Mar 20, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRRN241739

**Issuance Date:** Nov 25, 2024

**Property Address:** 1920 BRIDGE LN, UNIT:14;

**Applicant:** Karl Holt

**Contractor:**

**To construct:** Resolve violation notice Case #CE20220283 which was creating a new residential dwelling unit on the main floor, and level 2 of this unit.

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** All fire doors and rated assemblies are now installed and complete. All sub permit work is complete. Approved for TCO while property goes through planning department permit work.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us