



INSPECTION REPORT

Report Issued: Mar 24, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH241666

Issuance Date: Oct 22, 2024

Property Address: 3300 S LINCOLN AVE;

Applicant: JM Mechanical, LLC

Contractor: JM Mechanical, LLC 222 West 2850 North North Logan, UT 84341

To construct: New Hotel- 101 PTAC Units, 1 DOAS Unit, Daikin VRF System, Exhaust fans, Heaters, Air Curtains, Ductwork and Refrigeration

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: Supply / return air ducts and bathroom exhaust fans installed in all units and corridor on 2nd floor. All duct are properly supported and sealed. Smoke and fire dampers installed to plans. All ducts properly fire caulked in demising walls. Will need to see drywall repair in lid in unit 230. Partial approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us