



INSPECTION REPORT

Report Issued: Mar 26, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH250018

Issuance Date: Jan 10, 2025

Property Address: 355 RIVERVIEW WAY;

Applicant: Air Comfort, Inc.

Contractor: Air Comfort, Inc. 150 ROME COURT, 150 Rome Court FT. COLLINS, CO 80524

To construct: HVAC Mechanical

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: See correction for strapping dryer ducts, all other 2nd floor above ceiling duct work has been installed, supported and sealed correctly. 2nd and 1st floor AC line sets are installed correctly, pressure tests good. Partial approved.

Corrections:

- 1 Strap dryer ducts every 4'

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us