



INSPECTION REPORT

Report Issued: Mar 26, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL240967

Issuance Date: Jul 18, 2024

Property Address: 1550 AMBLE DR;

Applicant: Holly Klein

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: New plumbing for The Amble.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial; DWV installed to approved plans in unit 110 and passed test of 5psi.
Domestic water installed and passed tests of 100 psi in units
106 Kitchen and west bathrooms.
107 West bathrooms.
108 All fixtures except kitchen.
109 West bathroom, washer box and water vapor fireplace.
110 Complete minus kitchen.
111 Complete.

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us