



INSPECTION REPORT

Report Issued: Mar 27, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH250018

Issuance Date: Jan 10, 2025

Property Address: 355 RIVERVIEW WAY;

Applicant: Air Comfort, Inc.

Contractor: Air Comfort, Inc. 150 ROME COURT, 150 Rome Court FT. COLLINS, CO 80524

To construct: HVAC Mechanical

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Dryers now strapped correctly. Second floor rough mechanical approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us