



INSPECTION REPORT

Report Issued: Mar 27, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL240967

Issuance Date: Jul 18, 2024

Property Address: 1550 AMBLE DR;

Applicant: Holly Klein

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: New plumbing for The Amble.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: DWV installed to approved plans and passed pressure test of 5psi in units 109 and 111.

Domestic water lines installed and passed tests of 100psi in units

104 minus kitchen and risers.

106 east bathrooms.

107 east bathrooms

109 east bathrooms.

Partial approved

Corrections:

Sincerely,

Ron Norton
Inspector



rnorton@co.routt.co.us