



# INSPECTION REPORT

**Report Issued:** Mar 31, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRPL240967

**Issuance Date:** Jul 18, 2024

**Property Address:** 1550 AMBLE DR;

**Applicant:** Holly Klein

**Contractor:** MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

**To construct:** New plumbing for The Amble.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Roof drains on first floor outside unit 111 installed per approved plans and passed pressure test of 5psi. Approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us