



INSPECTION REPORT

Report Issued: Apr 02, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL240967

Issuance Date: Jul 18, 2024

Property Address: 1550 AMBLE DR;

Applicant: Holly Klein

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: New plumbing for The Amble.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: DWV in unit 106 completed to approved plans and passed pressure test of 6psi. Waterline riser in unit 106 completed for garage to second level and passed test of 100psi.

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us