



INSPECTION REPORT

Report Issued: Apr 21, 2025

Inspection Result: PASSED

Permit Number: SPRMH231646

Issuance Date: Nov 17, 2023

Property Address: 1855 SKI TIME SQUARE DR;

Applicant: R & H MECHANICAL, LLC

Contractor: R & H MECHANICAL, LLC P.O. BOX 810 EAGLE, CO 81631 (970) 328-2699

To construct: Torian Plum - Install new boiler & adding 4,810 square feet of snowmelt tubing, manifolds, etc.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All manifold connected in yard boxes and operational. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us