



INSPECTION REPORT

Report Issued: Apr 21, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH241666

Issuance Date: Oct 22, 2024

Property Address: 3300 S LINCOLN AVE;

Applicant: JM Mechanical, LLC

Contractor: JM Mechanical, LLC 222 West 2850 North North Logan, UT 84341

To construct: New Hotel- 101 PTAC Units, 1 DOAS Unit, Daikin VRF System, Exhaust fans, Heaters, Air Curtains, Ductwork and Refrigeration

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 1st floor staff rooms, duct work is sealed and supported, penetrations fire calked

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us