



INSPECTION REPORT

Report Issued: Apr 21, 2025

Inspection Result: PASSED

Permit Number: SPRMH240133

Issuance Date: Feb 10, 2024

Property Address: 2940 VILLAGE DR; 2944 VILLAGE DR; 2948 VILLAGE DR; 2956 VILLAGE DR; 2936 VILLAGE DR;

Applicant: CROSS MOUNTAIN PLMB & HEAT

Contractor: CROSS MOUNTAIN PLMB & HEAT P.O. BOX 771905 STEAMBOAT SPGS,, CO 80477 (970) 819-4276

To construct: Radiant heat system, snow melt system.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 4 Underground gas lines run to from southside of unit 2956 to units 2948, 2944, 2940, and 2936. All gas lines installed in trench of proper depth and all have trace wires. All 4 guages passed at 15psi. Approved to backfill.

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us