



INSPECTION REPORT

Report Issued: Apr 21, 2025

Inspection Result: NOT READY

Permit Number: SPRMH240133

Issuance Date: Feb 10, 2024

Property Address: 2940 VILLAGE DR; 2944 VILLAGE DR; 2948 VILLAGE DR; 2956 VILLAGE DR; 2936 VILLAGE DR;

Applicant: CROSS MOUNTAIN PLMB & HEAT

Contractor: CROSS MOUNTAIN PLMB & HEAT P.O. BOX 771905 STEAMBOAT SPGS,, CO 80477 (970) 819-4276

To construct: Radiant heat system, snow melt system.

On this day we have inspected your construction for **Approval for Gas Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments:

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us