



# INSPECTION REPORT

**Report Issued:** Apr 28, 2025

**Inspection Result:** PASSED

**Permit Number:** SPRMU230307

**Issuance Date:** Jul 21, 2023

**Property Address:** 1901 CURVE PLZ;

**Applicant:** May Riegler Properties, LLC (Gaby & Kevin Riegler)

**Contractor:** Steamboat Building Company, LLC 1195 BANGTAIL WAY, PO Box 774165  
STEAMBOAT SPRINGS, CO 80487 (970) 846-8995

**To construct:** Building 1 of Basecamp Townhomes. Includes seven (7) individual townhome units.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** All framing corrections were made before insulation started, ANSI Z97.1 safety film is installed in unit 1 landing window. All RFI's are in and engineers stamped letter.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us