



## **INSPECTION REPORT**

| ection Result: PARTIAL PASS |
|-----------------------------|
|                             |

Permit Number: SPRMH241666 Issuance Date: Oct 22, 2024

**Property Address:** 3300 S LINCOLN AVE;

Applicant: JM Mechanical, LLC

Contractor: JM Mechanical, LLC 222 West 2850 North North Logan, UT 84341

To construct: New Hotel- 101 PTAC Units, 1 DOAS Unit, Daikin VRF System, Exhaust fans,

Heaters, Air Curtains, Ductwork and Refrigeration

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** First floor duct work and fan coil mains, sealed and supported. Line sets, indoor manifold all holding 350-400 psi, outdoor blue and green lines holding @ 300 psi

## **Corrections:**

Sincerely,

Jeff Yeiser Inspector jyeiser@co.routt.co.us