

INSPECTION REPORT

Report Issued: May 07, 2025

Inspection Result: **FAILED**

Permit Number: SPRSW240383

Issuance Date: May 13, 2024

Property Address: 1750 CENTRAL PARK DR;

Applicant: Marc Imlay

Contractor: Rebecca Lindeman <NO STREET ADDRESS> CO David Jasinski <NO STREET ADDRESS> CO Justin Albert <NO STREET ADDRESS> CO

To construct: This project consists of the ground-up construction of a four-story hotel and associated site improvements.

On this day we have inspected your construction for **45 Day Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Complete corrections by May 14, 2025 and email photos once completed.

Corrections:

- 1 Further install erosion control blankets at Northwest sediment basin.
- 2 Install aggregate material at corner of entrance to prevent tracking.
- 3 Continue to pick up trash as needed.

Sincerely,

Scott Slamal
Stormwater Inspector
sslamal@steamboatsprings.net