



INSPECTION REPORT

Report Issued: May 13, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL240967

Issuance Date: Jul 18, 2024

Property Address: 1550 AMBLE DR;

Applicant: Holly Klein

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: New plumbing for The Amble.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: DWV completed to plans in unit 204 passed pressure test of 6psi. 204 Water riser south and middle and pex installed and passed 100psi test. Unit 203 east water riser and pex installed and passed test of 100psi. Partial approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us