



INSPECTION REPORT

Report Issued: May 14, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL240967

Issuance Date: Jul 18, 2024

Property Address: 1550 AMBLE DR;

Applicant: Holly Klein

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: New plumbing for The Amble.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: DWV in units 201,202 and 203 installed to approved plans and passed test of 6psi. DWV for RFI 491 stack for units 102, 202 and 303 passed test of 6psi. Water risers and pex tubing for 204 north 202 and 201 minus pex installed to approved plans and passed test of 98psi. Partial approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us