



INSPECTION REPORT

Report Issued: May 15, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL240967

Issuance Date: Jul 18, 2024

Property Address: 1550 AMBLE DR;

Applicant: Holly Klein

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: New plumbing for The Amble.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Re-inspected unit 201 for DWV and water lines, as there was a very small leak in air pressure in both yesterday, both DWW and water held 5psi and 100 psi for 15 minutes, approved unit 201.

Inspected Unit 311 DWV lines, all lines held 5psi or greater for 15 minutes, piping supported properly and unit 311 approve.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us