



# INSPECTION REPORT

**Report Issued:** May 19, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRPL240967

**Issuance Date:** Jul 18, 2024

**Property Address:** 1550 AMBLE DR;

**Applicant:** Holly Klein

**Contractor:** MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

**To construct:** New plumbing for The Amble.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** DWV for units 310 and 308 minus one 3 inch stack completed to approve plans and passed test of 6psi. Water risers in units 311, 310 and 309 east installed to fourth floor and passed tests of 100psi. Partial approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us