



INSPECTION REPORT

Report Issued: May 21, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL240967

Issuance Date: Jul 18, 2024

Property Address: 1550 AMBLE DR;

Applicant: Holly Klein

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: New plumbing for The Amble.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Water risers for units 308 and 309 installed to fourth floor and passed tests of 100psi. DWV for unit 309 and corrections in 310 installed to plans and passed tests of 6psi.

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us