



INSPECTION REPORT

Report Issued: May 21, 2025

Inspection Result: PASSED

Permit Number: SPRGS250646

Issuance Date: May 20, 2025

Property Address: 425 ANGLERS DR;

Applicant: PEAK MECHANICAL SERVICE

Contractor: PEAK MECHANICAL SERVICE 1730 13TH STREET STEAMBOAT SPGS, CO 80487
(970) 879-7753

To construct: got tagged to replace meter and pressure test, got system on pressure test,
need green tag for atmos to hook up meter
970-846-2786

On this day we have inspected your construction for **Gas Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Gas pressure test for meter hook up. Holding 15 psi

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us