



# INSPECTION REPORT

**Report Issued:** May 21, 2025

**Inspection Result:** PASSED

**Permit Number:** SPRGS250646

**Issuance Date:** May 20, 2025

**Property Address:** 425 ANGLERS DR;

**Applicant:** PEAK MECHANICAL SERVICE

**Contractor:** PEAK MECHANICAL SERVICE 1730 13TH STREET STEAMBOAT SPGS, CO 80487  
(970) 879-7753

**To construct:** got tagged to replace meter and pressure test, got system on pressure test,  
need green tag for atmos to hook up meter  
970-846-2786

On this day we have inspected your construction for **Gas Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Gas pressure test for meter hook up. Holding 15 psi

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us