



INSPECTION REPORT

Report Issued: May 22, 2025

Inspection Result: PASSED

Permit Number: SPRGS250621

Issuance Date: May 15, 2025

Property Address: 1875 SKI TIME SQUARE DR;

Applicant: ALPENGLOW PLUMBING & HEATING

Contractor: ALPENGLOW PLUMBING & HEATING 41560 CR 38A STEAMBOAT SPGS,, CO
80487

To construct: Meter has been unused and locked out for one year. No work done on
existing gas line, only new fire pits installed

On this day we have inspected your construction for **Gas Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Existing gas line test performed from meter to 4 four fire pits. Gas line test is good at 15psi, green tag issued

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us