



INSPECTION REPORT

Report Issued: May 23, 2025

Inspection Result: PASSED

Permit Number: SPRGS250412

Issuance Date: Apr 15, 2025

Property Address: 1855 SKI TIME SQUARE DR;

Applicant: Isidro Quezada

Contractor: IQ PLUMBING & HEATING 895 RANNEY ST CRAIG, CO 81625 (970) 629-5125

To construct: Replace existing 2" gas line and upsize it to 2-1/2" gas line that feeds a snowmelt boiler. Work to be done at Torian Plum Condominiums.

On this day we have inspected your construction for **Approval for Gas Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Gas line connected to boiler, green tag issued

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us