



# INSPECTION REPORT

**Report Issued:** May 23, 2025

**Inspection Result:** PASSED

**Permit Number:** SPRGS250412

**Issuance Date:** Apr 15, 2025

**Property Address:** 1855 SKI TIME SQUARE DR;

**Applicant:** Isidro Quezada

**Contractor:** IQ PLUMBING & HEATING 895 RANNEY ST CRAIG, CO 81625 (970) 629-5125

**To construct:** Replace existing 2" gas line and upsize it to 2-1/2" gas line that feeds a snowmelt boiler. Work to be done at Torian Plum Condominiums.

On this day we have inspected your construction for **Gas Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Gas line complete, connected to boiler

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us