



# INSPECTION REPORT

**Report Issued:** May 29, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRPL240967

**Issuance Date:** Jul 18, 2024

**Property Address:** 1550 AMBLE DR;

**Applicant:** Holly Klein

**Contractor:** MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

**To construct:** New plumbing for The Amble.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Partial: DWV for units 305 and 307 installed to approved plans and passed test of 6psi. Water risers installed units 305 and 309 west completed and passed tests of 100psi. Partial approved.

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us