



INSPECTION REPORT

Report Issued: May 29, 2025

Inspection Result: PASSED

Permit Number: SPREL250417

Issuance Date: Apr 16, 2025

Property Address: 1900 BRIDGE LN, UNIT:2A;

Applicant: NORTHWEST ELECTRICAL SYSTEMS

Contractor: NORTHWEST ELECTRICAL SYSTEMS P.O. BOX 393 YAMPA, CO 80483

To construct: accepting responsibility on work not inspected

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Final electrical approved note 2017 code cycle referenced as date of installation

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us