



INSPECTION REPORT

Report Issued: May 29, 2025

Inspection Result: PASSED

Permit Number: SPREL240531

Issuance Date: May 16, 2024

Property Address: 322 RIVERVIEW WAY;

Applicant: CENTRAL ELECTRIC, LLC

Contractor: CENTRAL ELECTRIC, LLC 2659 Jacob Cir #4 STEAMBOAT SPGS,, CO 80487
(970) 846-8379

To construct: Riverview Bldg B
New wiring, service, devices, lighting, etc.

On this day we have inspected your construction for **Electrical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Rough for RDP3 and rdb4 approved okay to energize

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us