



INSPECTION REPORT

Report Issued: Jun 05, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH241850

Issuance Date: Dec 03, 2024

Property Address: 1550 AMBLE DR;

Applicant: Holly Klein

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: The Amble - Mechanical system, new build

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial: Snowmelt zones 1, 2 and 3 have mains installed for mechanical room to exterior manifold locations. All zones passed test of 80psi. All pipe are properly supported. Partial approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us