



# INSPECTION REPORT

**Report Issued:** Jun 09, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRPL241751

**Issuance Date:** Nov 03, 2024

**Property Address:** 1760 CENTRAL PARK DR;

**Applicant:** L&R PLUMBING INC

**Contractor:** L&R PLUMBING INC 2306 WINFORD AVENUE NASHVILLE, TN 37211 (615) 349-5773

**To construct:** New Restaurant Plumbing, gas, water, 3,488 Sq Ft  
STOP WORK ORDER generated on 04/15/2025 by username 'Todd Carr'.  
STOP WORK ORDER removed on 05/06/2025 by username 'Barbara Fox'.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Interceptor, water tested from building to main, no visible leaks

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us