



INSPECTION REPORT

Report Issued: Jun 12, 2025

Inspection Result: PARTIAL PASS

Permit Number: SPRPL240967

Issuance Date: Jul 18, 2024

Property Address: 1550 AMBLE DR;

Applicant: Holly Klein

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: New plumbing for The Amble.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial; Unit 302 DWV installed to approved plans and passed test of 6psi and waterlines passed at 100psi. Risers and pex tubing in units 303, 304 powderroom, 306, 305 guest and 308 guest all passed test of 100psi. Partial approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us