



INSPECTION REPORT

Report Issued: Jun 12, 2025

Inspection Result: PARTIAL PASS

Permit Number: SPRPL240545

Issuance Date: May 17, 2024

Property Address: 322 RIVERVIEW WAY;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: Building B New Plumbing install

On this day we have inspected your construction for **Approval for Gas Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Gas lines have been installed and supported correctly per approved plans. Pressure test good at 15 psi for 15 minutes. First unit heater that is hooked up gas line and has vent through roof will need termination cap and elbow install and venting install manual before a green tag can be issued. Partial approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us