



INSPECTION REPORT

Report Issued: Jun 16, 2025

Inspection Result: PARTIAL PASS

Permit Number: SPREL240531

Issuance Date: May 16, 2024

Property Address: 322 RIVERVIEW WAY;

Applicant: CENTRAL ELECTRIC, LLC

Contractor: CENTRAL ELECTRIC, LLC 2659 Jacob Cir #4 STEAMBOAT SPGS,, CO 80487
(970) 846-8379

To construct: Riverview Bldg B
New wiring, service, devices, lighting, etc.

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Unit 415 missing cover plate over dryer. Unit 16 laundry area has a GFI receptacle but no arc fault protection. Here at 13 missing cover plate on kitchen counter. 414 missing switch cover and laundry area. For 11 missing cover plates under. sink. 409 missing cover cover plate for dryer receptacle. 410 receptacle and laundry area lacking our fault protection. 408 convenience receptacle in laundry room non-functional.kl0

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us