



INSPECTION REPORT

Report Issued: Jun 18, 2025

Inspection Result: PASSED

Permit Number: SPRPL240545

Issuance Date: May 17, 2024

Property Address: 322 RIVERVIEW WAY;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: Building B New Plumbing install

On this day we have inspected your construction for **Approval for Gas Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Unit heater termination now has 4' clearance from windows on second floor. Green tag issued.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us