



INSPECTION REPORT

Report Issued: Jun 19, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH250510

Issuance Date: Apr 28, 2025

Property Address: 3300 S LINCOLN AVE;

Applicant: HAZLETT PLUMBING AND HEATING, INC.

Contractor: HAZLETT PLUMBING AND HEATING, INC. PO BOX 881958 STEAMBOAT
SPRINGS, CO 80488 (970) 819-5353

To construct: Snow Melt on driveway & sidewalk

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Snow melt tubing, tied over foam board, holding 100 psi

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us