



INSPECTION REPORT

Report Issued: Jun 26, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH241850

Issuance Date: Dec 03, 2024

Property Address: 1550 AMBLE DR;

Applicant: Holly Klein

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: The Amble - Mechanical system, new build

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Above ceiling units and insulated duct in units 305 306 307 is good Above ceiling 8" insulated duct corridor is good Unit 411 above ceiling main supply and above ceiling duct in loft is good

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us