



INSPECTION REPORT

Report Issued: Jun 27, 2025

Inspection Result: PASSED

Permit Number: SPRPO241042

Issuance Date: Jun 24, 2025

Property Address: 1550 AMBLE DR;

Applicant: Jamie SchwarzHolly Klein

Contractor: Saunders Construction, LLC 86 Inverness Place North Englewood, CO 80112
MTech Mechanical Technologies Group 12300 Pecos Street Westminster, CO 80234 (719) 782-4000

To construct: This is the Pool Permit for all work done under the associated Building Permit SPRMU231779, all fees have been paid through the main building permit. This permit is to recognize the pool being installed and to have plan reviews done by the Routt County Environmental Health Department and Routt County Regional Building Department for pool piping and equipment, and State of Colorado Standards that are required to be reviewed by the Routt County Environmental Health Department.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All circulation piping for pool installed to approved plans. Piping run into pool mech room and all passed tests of 35psi. Approved, Ok to cover

Corrections:

Sincerely,

Ron Norton



Inspector
rnorton@co.routt.co.us