



# INSPECTION REPORT

**Report Issued:** Jun 30, 2025

**Inspection Result:** PASSED

**Permit Number:** SPRMH231629

**Issuance Date:** Nov 08, 2023

**Property Address:** 1901 CURVE PLZ;

**Applicant:** MOUNTAIN HIGH MECHANICAL

**Contractor:** Steamboat Building Company, LLC 1195 BANGTAIL WAY, PO Box 774165  
STEAMBOAT SPRINGS, CO 80487 (970) 846-8995

**To construct:** Will supply electric water heater. Will supply bathroom exhaust fans and kitchen fans. All bath fans, kitchen exhaust fans, and dryers will be vented will install 2 furnaces paired with evaporator coil and condenser.

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** All mechanical work is complete. Final approved.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us