



INSPECTION REPORT

Report Issued: Jul 02, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPREL241797

Issuance Date: Nov 15, 2024

Property Address: 200 SUNDANCE CT;

Applicant: GOAT Electric LTD

Contractor: GOAT Electric LTD 2316 N. Wahsatch Ave. #104, 2316 N. Wahsatch Ave. #104,
Colorado Springs Colorado Springs, CO 80907 (719) 229-0252

To construct: Electrical for:
UNIT A: 200 Sundance Ct
SPRSF241394

On this day we have inspected your construction for **Electrical Perm Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Upon inspection both services are correct but the county is unable to energize Services until the interior rough is complete. Permanent service will be approved when rough electric is complete

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us