



# INSPECTION REPORT

**Report Issued:** Jul 15, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRMH250510

**Issuance Date:** Apr 28, 2025

**Property Address:** 3300 S LINCOLN AVE;

**Applicant:** HAZLETT PLUMBING AND HEATING, INC.

**Contractor:** HAZLETT PLUMBING AND HEATING, INC. PO BOX 881958 STEAMBOAT  
SPRINGS, CO 80488 (970) 819-5353

**To construct:** Snow Melt on driveway & sidewalk

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Snow melt , entry drive, holding 100 psi through the manifold

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us