



INSPECTION REPORT

Report Issued: Jul 16, 2025

Inspection Result: PARTIAL PASS

Permit Number: SPRPL241239

Issuance Date: Aug 21, 2024

Property Address: 1760 CENTRAL PARK DR;

Applicant: L&R PLUMBING INC

Contractor: L&R PLUMBING INC 2306 WINFORD AVENUE NASHVILLE, TN 37211 (615) 349-5773

To construct: New Plumbing Installation for new hotel
STOP WORK ORDER generated on 04/15/2025 by username 'Todd Carr'.
STOP WORK ORDER removed on 05/06/2025 by username 'Barbara Fox'.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All DWV tested with water to roof in all units on all floors except 2 mock units with no leaks detected. Water lines tested and approved at 100psi in all units on all floor except mock up units and common areas on 1st floor. Tubs and showers water test and approved in all units on 2nd, 3rd and 4th floor units on SHS side of building. still need to test tubs and showers on 1st floor on SHS side of building and all floors of TPS side of building. Partial approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us