



INSPECTION REPORT

Report Issued: Jul 17, 2025

Inspection Result: PARTIAL PASS

Permit Number: SPRMH241850

Issuance Date: Dec 03, 2024

Property Address: 1550 AMBLE DR;

Applicant: Holly Klein

Contractor: MTech Mechanical Technologies Group 12300 Pecos Street Westminster, Co 80234 (719) 782-4000

To construct: The Amble - Mechanical system, new build

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Partial; Third floor has all missing heat pumps and ERV installed from previous inspection. All ducts on third floor are now properly insulated.

Partial: Ducts installed, sealed and supported in units

410 above fire lid

410 under dormer slab

409 under dormer slab

409 above dormer fire lid

408 above dormer fire lid

408 under dormer slab.

Corrections:

Sincerely,

Ron Norton
Inspector



rnorton@co.routt.co.us