



# INSPECTION REPORT

**Report Issued:** Jul 18, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRPL240545

**Issuance Date:** May 17, 2024

**Property Address:** 322 RIVERVIEW WAY;

**Applicant:** Bellyache Mechanical

**Contractor:** Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

**To construct:** Building B New Plumbing install

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** units 301, 302, 303, 305, 306, 307, 308, 309 Plumbing finals complete for these units

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us