



# INSPECTION REPORT

**Report Issued:** Jul 22, 2025

**Inspection Result:** PASSED

**Permit Number:** SPRMH251066

**Issuance Date:** Jul 18, 2025

**Property Address:** 1920 BRIDGE LN, UNIT:13B;

**Applicant:** FIN'S TIN

**Contractor:** FIN'S TIN PO BOX 697 CLARK, CO 80428 (970) 846-7640

**To construct:** Install & Vent to the outside one Bath Fan.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** New bath fan installed on main level bathroom, fan installed in wall and is a 1-hour rated fire damper, duct work approved ran out the front of building with all duct sealed and supported properly.

**Corrections:**

Sincerely,

Todd Carr  
Building Official  
tcarr@co.routt.co.us