



# INSPECTION REPORT

**Report Issued:** Aug 07, 2025

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** SPRPL240545

**Issuance Date:** May 17, 2024

**Property Address:** 322 RIVERVIEW WAY;

**Applicant:** Bellyache Mechanical

**Contractor:** Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

**To construct:** Building B New Plumbing install

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Units 201 and 202 approved for finals for kitchens, bathrooms and laundry, please note tub spouts must be secured tightly so we cannot pull them in or out or turn them when light force is applied, same is true for shower heads, we had one tub spout that needs to be tightened in 202.

**Corrections:**

Sincerely,

Todd Carr  
Building Official  
tcarr@co.routt.co.us