



INSPECTION REPORT

Report Issued: Aug 11, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRPL240545

Issuance Date: May 17, 2024

Property Address: 322 RIVERVIEW WAY;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: Building B New Plumbing install

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Plumbing final for units 211, 213, 212, 215, 214,217,216,221. Please make sure all water lines are securely fastened in the wall so that we cannot pull water lines out of a wall, this happened in a kitchen cabinet on the sink lines, and also a toilet valve line, all water lines should have been secured during rough in.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us