



INSPECTION REPORT

Report Issued: Aug 12, 2025

Inspection Result: PARTIAL PASS

Permit Number: SPRPL241239

Issuance Date: Aug 21, 2024

Property Address: 1760 CENTRAL PARK DR;

Applicant: L&R PLUMBING INC

Contractor: L&R PLUMBING INC 2306 WINFORD AVENUE NASHVILLE, TN 37211 (615)
349-5773

To construct: New Plumbing Installation for new hotel
STOP WORK ORDER generated on 04/15/2025 by username 'Todd Carr'.
STOP WORK ORDER removed on 05/06/2025 by username 'Barbara Fox'.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All tubs and showers have been flood tested except mock up units and unit right below mock up units. All held water. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us