



INSPECTION REPORT

Report Issued: Aug 21, 2025

Inspection Result: **PARTIAL PASS**

Permit Number: SPRMH250017

Issuance Date: Jan 10, 2025

Property Address: 322 RIVERVIEW WAY;

Applicant: Air Comfort, Inc.

Contractor: Deneuve Design, Inc dba Deneuve Consrt. Serv 2344 Spruce Strt Ste B
Boulder, Co 80302

To construct: Mechanical HVAC

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Air handler duct work in spa and fitness room sealed and supported

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us