



INSPECTION REPORT

Report Issued: Sep 10, 2025

Inspection Result: PASSED

Permit Number: SPRPL240546

Issuance Date: May 17, 2024

Property Address: 355 RIVERVIEW WAY;

Applicant: Bellyache Mechanical

Contractor: Bellyache Mechanical PO BOX 82 Wolcott , CO 81655 (970) 470-3341

To construct: Building E New Plumbing Install

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Hangers have been added in the correct locations.

Corrections:

Sincerely,

Todd Carr
Building Official
tcarr@co.routt.co.us